



SSI Reg. No.: 33 001 21 00223  
Dt: 26-07-2007

# EKDANT ENVIRO SERVICES (P) LIMITED

An ISO 9001-2008 Certified Organization  
Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)  
ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING

No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101. India

Phone : 044 - 26540135 Mobile : 9444411178

E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in

Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT				
Sample Ref No. : 081/09			Report No. : 042/09	
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 14.09.13 Page: 1 of 1	
Sample Description : Sewage Water			Received On : 11.09.13	
Sample Drawn By : Customer/11.09.13			Commenced On : 11.09.13	
Customer's Reference : Letter Dated On 11.09.13			Completed On : 14.09.13	
Sample Mark : S.No.2 - STP Treated Water				
Sampling Location : Prince Residencia				
Sl. No	PARAMETERS	RESULTS	Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
1	Total Suspended Solids (mg/l)	10.0	30	IS:3025: P.17:1984.R.2006
2	BOD at 27°C for 3 days (mg/l)	BDL (DL=2.0)	20	IS: 3025 P. 44 1993 R. 2009
BDL-Below Detectable Limit: DL-Detection Limit				
End of Report				
Verified By:		for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division		
R. Nirmala Devi Deputy Technical Manager		M. Maria Frank Omer - Quality Cum Tech. Manager		

## NOTE:

1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.





SSI Reg. No.: 33 001 21 00223  
Dt : 26-07-2007

# EKDANT ENVIRO SERVICES (P) LIMITED

An ISO 9001-2008 Certified Organization  
Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)  
ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING

No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101. India

Phone : 044 - 26540135 Mobile : 9444411178

E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in

Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT				
Sample Ref No. : 052/10			Report No. : 016/10	
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 07.10.13 Page: 1 of 1	
Sample Description : Sewage Water Sample Drawn By : Customer/04.10.13 Customer's Reference : Letter Dated On 04.10.13 Sample Mark : STP Treated Water Sampling Location : Jain Sundarbans			Received On : 04.10.13 Commenced On : 04.10.13 Completed On : 07.10.13	
Sl. No	PARAMETERS	RESULTS	Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
1	Total Suspended Solids (mg/l)	<1.0	30	IS:3025: P.17:1984;R.2006
2	BOD at 27°C for 3 days (mg/l)	BDL (DL=2.0)	20	IS: 3025 P. 44 1993 R. 2009
BDL-Below Detectable Limit: DL-Detection Limit				
End of Report				
Verified By:		for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division		
R. Nirmala Devi Deputy Technical Manager		M. Maria Frank Omer - Quality Cum Tech. Manager		

**NOTE:**

1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.





SSI Reg. No.: 33 001 21 00223  
Dt : 26-07-2007

# EKDANT ENVIRO SERVICES (P) LIMITED

An ISO 9001-2008 Certified Organization

Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)

ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING

No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101. India




Phone : 044 - 26540135 Mobile : 9444411178

E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in

Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT					
Sample Ref No. : 170/10 to 171/10			Report No. : 086/10 to 087/10		
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 21.10.13 Page: 1 of 1		
Sample Description : Sewage Water			Received On : 17.10.13		
Sample Drawn By : Customer/17.10.13			Commenced On : 17.10.13		
Customer's Reference : Letter Dated On 17.10.13			Completed On : 21.10.13		
Sample Mark : STP Treated Water					
Sampling Location : Prince Infocity K1					
Sl. No	PARAMETERS	RESULTS		Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
		Before Filter	After Filter		
1	Total Suspended Solids (mg/l)	8.0	3.0	30	IS:3025: P.17:1984:R.2006
2	BOD at 27°C for 3 days (mg/l)	2.0	BDL (DL=2.0)	20	IS: 3025 P. 44 1993 R. 2009
BDL-Below Detectable Limit: DL-Detection Limit					
End of Report					
Verified By:			for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division		
 R. Nirmala Devi Deputy Technical Manager			  Authorized Signatory M. Maria Frank Omer – Quality Cum Tech Manager		

**NOTE:**

1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.



# EKDANT ENVIRO SERVICES (P) LIMITED

SSI Reg. No.: 33 001 21 00223  
Dt: 26-07-2007

An ISO 9001-2008 Certified Organization  
Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)  
ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING

No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101. India

Phone : 044 - 26540135 Mobile : 9444411178

E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in

Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT					
Sample Ref No. : 172/10 to 173/10			Report No. : 088/10 to 089/10		
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 21.10.13 Page: 1 of 1		
Sample Description : Sewage Water Sample Drawn By : Customer/17.10.13 Customer's Reference : Letter Dated On 17.10.13 Sample Mark : STP Treated Water Sampling Location : Prince Infocity K2			Received On : 17.10.13 Commenced On : 17.10.13 Completed On : 21.10.13		
Sl. No	PARAMETERS	RESULTS		Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
		Before Filter	After Filter		
1	Total Suspended Solids (mg/l)	22.0	4.0	30	IS:3025: P.17:1984:R.2006
2	BOD at 27°C for 3 days (mg/l)	4.0	BDL (DL=2.0)	20	IS: 3025 P.44 1993 R. 2009
BDL-Below Detectable Limit: DL-Detection Limit					
End of Report					
Verified By:  R. Nirmala Devi Deputy Technical Manager			for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division  Authorized Signatory M. Maria Frank Omer – Quality Cum Tech Manager		

**NOTE:**

1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.





SSI Reg. No.: 33 001 21 00223  
Dt: 26-07-2007

# EKDANT ENVIRO SERVICES (P) LIMITED

An ISO 9001-2008 Certified Organization  
Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)  
ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING  
No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101, India  
Phone : 044 - 26540135 Mobile : 9444411178  
E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in  
Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT				
Sample Ref No. : 005/02			Report No. : 003/02	
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 04.02.14 Page: 1 of 1	
Sample Description : Sewage Water			Received On : 01.02.14	
Sample Drawn By : Customer/01.02.14			Commenced On : 01.02.14	
Customer's Reference : Letter Dated On 01.02.14			Completed On : 04.02.14	
Sample Mark : STP Treated Water				
Sampling Location : TRT,Prince Village, Tondaiyarpet				
Sl. No	PARAMETERS	RESULTS	Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
1	Total Suspended Solids (mg/l)	1.0	30	IS:3025:P.17:1984:R.2006
2	BOD at 27°C for 3 days (mg/l)	BDL (DL=2.0)	20	IS: 3025 P. 44 1993 R. 2009
BDL-Below Detectable Limit: DL-Detection Limit.				
End of Report				
Verified By:		for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division		
R. Nirmala Devi Deputy Technical Manager		M. Maria Frank Omer – Quality Cum Tech Manager		

**NOTE:**

1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.



# EKDANT ENVIRO SERVICES (P) LIMITED

SSI Reg. No.: 33 001 21 00223  
Dt: 26-07-2007

An ISO 9001-2008 Certified Organization  
Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)  
ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING  
No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101. India  
Phone : 044 - 26540135 Mobile : 9444411178  
E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in  
Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT				
Sample Ref No. : 029/02			Report No. : 020/02	
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 07.02.14 Page: 1 of 1	
Sample Description : Sewage Water			Received On : 04.02.14	
Sample Drawn By : Customer/04.02.14			Commenced On : 04.02.14	
Customer's Reference : Letter Dated On /04.02.14			Completed On : 07.02.14	
Sample Mark : STP Treated Water				
Sampling Location : Prince Info Park,Ambattur				
Sl. No	PARAMETERS	RESULTS	Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
1	Total Suspended Solids (mg/l)	22.0	30	IS:3025: P.17:1984:R.2006
2	BOD at 27°C for 3 days (mg/l)	4.0	20	IS: 3025 P. 44 1993 R. 2009
End of Report				
Verified By:   R. Nirmala Devi Deputy Technical Manager			for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division   Authorized Signatory M. Maria Frank Omer – Quality Cum Tech. Manager	

- NOTE:
1. Test results shown in this test report relate only to the items tested.
  2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
  3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.





# EKDANT ENVIRO SERVICES (P) LIMITED

SSI Reg. No.: 33 001 21 00223  
Dt: 26-07-2007

An ISO 9001-2008 Certified Organization  
Govt. Reg.No. (Registrar of Firms Chennai Central - 501 of 2005)  
ISO/IEC 17025 : 2005 ACCREDITED BY NABL FOR CHEMICAL & BIOLOGICAL TESTING  
No.28/41, Park Road, Anna Nagar West Extn., Chennai - 600 101. India  
Phone : 044 - 26540135 Mobile : 9444411178  
E-mail : ekdantlab@gmail.com / info@ekdantlab.co.in  
Web : www.ekdantlab.co.in



C No.:T-1574,T-1575

TEST REPORT				
Sample Ref No. : 004/02			Report No. : 002/02	
Issued To: M/s.3R Technology No.12/6,Cross Reddy Street, Athipet,Chennai-58			Report Date : 04.02.14 Page: 1 of 1	
Sample Description : Sewage Water			Received On : 01.02.14	
Sample Drawn By : Customer/01.02.14			Commenced On : 01.02.14	
Customer's Reference : Letter Dated On 01.02.14			Completed On : 04.02.14	
Sample Mark : STP Treated Water				
Sampling Location : TRT-K1,Prince Info City-K1				
Sl. No	PARAMETERS	RESULTS	Tolerance limits for Treated Outlet as per TNPCB	PROTOCOL:
1	Total Suspended Solids (mg/l)	2.0	30	IS:3025: P.17:1984:R.2006
2	BOD at 27°C for 3 days (mg/l)	BDL (DL=2.0)	20	IS: 3025 P. 44 1993 R. 2009
BDL-Below Detectable Limit: DL-Detection Limit.				
End of Report				
Verified By:		for EKDANT ENVIRO SERVICES (P) LTD Laboratory Services Division		
R. Nirmala Devi Deputy Technical Manager		M. Maria Frank Omer – Quality Cum Tech Manager		

**NOTE:**

1. Test results shown in this test report relate only to the items tested.
2. This test report shall not be reproduce anywhere except in full and in same format without the approval of the laboratory
3. Unless informed by the customer the test items will not be retained for more than 7 days from the date of issue of test report.